Component Schedule	Component Name	Primary Fire Stopping Product	Applicable Substrates	Min Substrate Thickness (If Applicable)	Applicable FRL	Service Specifications	Limitations
1 2 3 4	FR Plasterboard, Concrete or Masonry FireMastic-300™ - 50mm x 50mm Surface Fillet 60.3mm OD Steel Sprinkler Pipe - 10mm Annular Gap Steel Stud	FireMastic-300™	FR Plasterboard, Concrete, Masonry	Min 116mm Thick	-/120/120	50mm Steel Sprinkler Pipe (60.3mm OD)	80mm Aperture
		Secondary Fire Stopping Product					
		Tertiary Fire Stopping Product					

BOSS PASSIVE FIRE

Sales & Technical	1300 502 677
International	+61 2 9531 8591
Web	bossfire.com

Drawing Information:

Category 1	Wall
Category 2	Service Penetration
Category 3	Metal Pipes
Test Standard	AS1530.4-2014/AS4072.1
Test Reference	SFC FRT180473a.1
Drawing Number	W-SP-MET-009
Product DWG ID	FM3-010
Drawn By	EG	**Rev**	03
Date of Issue	07/12/2020